

**WaterPro, Inc.**  
**Consumer Confidence Report Data**  
**2013**

This table lists all of the parameters in the drinking water detected by WaterPro or its suppliers in the drinking water during the calendar year of this report. The presence of these parameters in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of this report. For certain parameters, EPA and/or the State requires monitoring at a frequency less than once per year because the concentrations do not change frequently.

Parameter	Units	2013 Avg	2013 Max	2013 Min	Monitoring Criteria			Last Sampled	Comments/Likely Source
					MCL	MCLG	Violation		
<b>PRIMARY INORGANICS</b>									
Antimony	ug/L	ND	ND	ND	6.00	6.00	No	2013	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder.
Arsenic	ug/L	0.8	2.9	ND	10.0	0.0	No	2013	Erosion of naturally occurring deposits and runoff from orchards.
Asbestos	MFL	ND	ND	ND	7.0	7.0	No	2011	Decay of asbestos cement in water mains; erosion of natural deposits.
Barium	ug/L	109	203	55	2000	2000	No	2013	Erosion of naturally occurring deposits.
Beryllium	ug/L	ND	ND	ND	4	4	No	2013	Discharge from metal refineries and coal burning factories.
Cadmium	ug/L	ND	ND	ND	5.00	5.00	No	2013	Corrosion of galvanized pipes; erosion of natural deposits.
Copper	ug/L	1	5	ND	NE	NE	No	2013	Erosion of naturally occurring deposits.
Chromium	ug/L	ND	ND	ND	100.0	100.0	No	2013	Discharge from steel and pulp mills; Erosion of natural deposits.
Cyanide, Free	ug/L	ND	ND	ND	200.0	200.0	No	2011	Discharge from steel/metal factories; discharge from plastic and fertilizer factories.
Fluoride	mg/L	0.7	1.0	0.2	4.0	4.0	No	2013	Erosion of naturally occurring deposits and discharges from fertilizers. Fluoride added at source.
Lead	ug/L	0.1	0.5	ND	NE	NE	No	2013	Erosion of naturally occurring deposits.
Mercury	ug/L	0.03	0.20	ND	2.00	2.00	No	2013	Erosion of naturally occurring deposits and runoff from landfills.
Nickel	ug/L	ND	ND	ND	NE	NE	No	2013	Erosion of naturally occurring deposits.
Nitrate	mg/L	2.1	3.7	0.3	10.0	10.0	No	2013	Runoff from fertilizer, leaching from septic tanks, and naturally occurring organic material.
Nitrite	mg/L	ND	ND	ND	1.0	1.0	No	2013	Runoff from fertilizer, leaching from septic tanks, and naturally occurring organic material.
Selenium	ug/L	1.0	3.1	ND	50.0	50.0	No	2013	Erosion of naturally occurring deposits.
Sodium	mg/L	23.1	79.9	5.4	NE	NE	No	2013	Erosion of naturally occurring deposits and runoff from road deicing.
Sulfate	mg/L	30	100	3	1000	NE	No	2013	Erosion of naturally occurring deposits.
Thallium	ug/L	ND	ND	ND	2.0	0.5	No	2013	Leaching from ore-processing sites, discharges from electronics, glass and drug factories.
TDS	mg/L	284	688	32	2000	NE	No	2013	Erosion of naturally occurring deposits.
Turbidity (groundwater sources)	NTU	0.46	2.84	0.02	5.0	NE	No	2013	MCL is 5.0 for groundwater. Suspended material from soil runoff.
Turbidity (surface water sources)	NTU	0.04	0.29	0.03	0.3	TT	No	2013	MCL is 0.3 NTU 95% of the time for surface water. Suspended material from soil runoff.
Lowest Monthly % Meeting TT	%	100% (Treatment Technique requirement applies only to treated surface water sources)							
<b>SECONDARY INORGANICS - Aesthetic Standards</b>									
Aluminum	ug/L	ND	ND	ND	SS = 50-200	NE	No	2011	Erosion of naturally occurring deposits and treatment residuals.
Chloride	mg/L	53	170	9	SS = 250	NE	No	2013	Erosion of naturally occurring deposits.
Iron	ug/L	33	200	ND	SS = 300	NE	No	2013	Erosion of naturally occurring deposits.
Manganese	ug/L	ND	ND	ND	SS = 50	NE	No	2013	Erosion of naturally occurring deposits.
pH		7.7	8.3	6.6	SS = 6.5-8.5	NE	No	2013	Naturally occurring.
Silver	ug/L	ND	ND	ND	SS = 100	NE	No	2013	Erosion of naturally occurring deposits.
Zinc	ug/L	ND	ND	ND	SS = 5000	NE	No	2013	Erosion of naturally occurring deposits.
<b>UNREGULATED PARAMETERS - monitoring not required</b>									
Alkalinity, Bicarbonate	mg/L	152	288	60	UR	NE	No	2013	Naturally occurring.
Alkalinity, Carbonate	mg/L	ND	ND	ND	UR	NE	No	2013	Naturally occurring.
Alkalinity, CO <sub>2</sub>	mg/L	112	212	45	UR	NE	No	2013	Naturally occurring.
Alkalinity, Hydroxide	mg/L	ND	ND	ND	UR	NE	No	2013	Naturally occurring.
Alkalinity, Total (CaCO <sub>3</sub> )	mg/L	125	236	13	UR	NE	No	2013	Naturally occurring.
Bromide	ug/L	0.09	0.09	0.09	UR	NE	No	2013	Naturally occurring.
Calcium	mg/L	44	84	15	UR	NE	No	2013	Erosion of naturally occurring deposits.
Conductance	umhos/cm	480	917	39	UR	NE	No	2013	Naturally occurring.
Cyanide, Total	ug/L	ND	ND	ND	UR	NE	No	2013	Discharge from steel/metal factories; discharge from plastic and fertilizer factories.
Geosmin	ng/L	1.6	6.8	ND	UR	NE	No	2013	Naturally occurring organic compound associated with musty odor.
Hardness, Calcium	mg/L	124	170	12	UR	NE	No	2013	Erosion of naturally occurring deposits.
Hardness, Total	mg/L	168	402	16	UR	NE	No	2013	Erosion of naturally occurring deposits.
Chromium VI	mg/L	ND	ND	ND	UR	NE	No	2011	Industrial runoff and naturally occurring.
Magnesium	mg/L	14.5	47.0	2.7	UR	NE	No	2013	Erosion of naturally occurring deposits.

Orthophosphates	ug/L	3.3	20.0	ND	UR	NE	No	2013	Erosion of naturally occurring deposits.
Potassium	mg/L	4.4	14.0	1.2	UR	NE	No	2013	Erosion of naturally occurring deposits.
TSS (Total Suspended Solids)	mg/L	1	4	ND	UR	NE	No	2013	Erosion of naturally occurring deposits.
<b>VOCs</b>									
Chloroform	ug/L	2.4	9.3	ND	UR	NE	No	2013	By-product of drinking water disinfection.
Dibromochloromethane	ug/L	0.3	1.4	ND	UR	NE	No	2013	By-product of drinking water disinfection.
Bromodichloromethane	ug/L	1.1	5.5	ND	UR	NE	No	2013	By-product of drinking water disinfection.
All Other Parameters	ug/L	None Detected			Various	Various	No	2013	Various sources.
<b>PESTICIDES/PCBs/SOCs</b>									
All Parameters	ug/L	None Detected			Various	Various	No	2013	Various sources.
<b>RADIOLOGICAL</b>									
Radium 226	pCi/L	0.10	0.25	0.01	NE	NE	No	2013	Decay of natural and man-made deposits.
Radium 228	pCi/L	0.55	1.10	-0.06	NE	NE	No	2013	Decay of natural and man-made deposits.
Radium 226 & 228	pCi/L	0.65	1.14	-0.05	5.00	NE	No	2013	Decay of natural and man-made deposits.
Gross-Alpha	pCi/L	5.5	12.8	0.4	15.0	NE	No	2013	Decay of natural and man-made deposits.
Gross-Beta	pCi/L	7.1	14.0	3.8	50.0	NE	No	2013	Decay of natural and man-made deposits.
Uranium	ug/L	7.3	12.0	ND	30.0	NE	No	2013	Erosion of naturally occurring deposits.
Radon	pCi/L	-8.0	-8.0	-8.0	NE	NE	No	2013	Naturally occurring in soil.
<b>DISINFECTANTS / DISINFECTION BY-PRODUCTS</b>									
Chlorine	mg/L	0.4	1.1	0.0	4.0	NE	No	2013	Drinking water disinfectant.
TTHMs	ug/L	23.7	48.6	ND	80.0	NE	No	2013	By-product of drinking water disinfection.
HAA5s	ug/L	14.8	32.8	ND	60.0	NE	No	2013	By-product of drinking water disinfection.
Highest Annual Location Wide Avg.	ug/L	TTHM = 38.9 ug/L, HAA5s = 24.85 ug/L							
Bromate	ug/L	ND	ND	ND	10.0	NE	No	2013	By-product of drinking water disinfection.
Chlorite	mg/L	0.34	0.51	ND	1.00	0.80	No	2013	By-product of drinking water disinfection.
<b>ORGANIC MATERIAL</b>									
Total Organic Carbon	mg/L	1.5	2.2	0.7	TT	NE	No	2013	Naturally occurring.
UV-254	1/cm	0.025	0.041	0.011	UR	NE	No	2013	Measure of the concentration of UV-absorbing organic compounds. Naturally occurring.
<b>LEAD and COPPER (tested at the consumer's tap) - monitoring required every 3 years.</b>									
Lead	ug/L	5	87	ND	AL = 15	NE	No	2013	Lead violation is determined by the 90th percentile result. Corrosion of household plumbing systems, erosion of naturally occurring deposits.
Copper	ug/L	114	370	11	AL = 1300	NE	No	2013	Copper violation is determined by the 90th percentile result. Corrosion of household plumbing systems, erosion of naturally occurring deposits.
90th Percentile		Lead = 4.2 ppb, Copper = 258 ppb							
# of sites above Action Level		Lead = 2, Copper = 0							
<b>PROTOZOA (sampled at source water)</b>									
Cryptosporidium	Oocysts/1L	ND	ND	ND	TT	0.00	No	2013	Parasite that enters lakes and rivers through sewage and animal waste.
Giardia	Cysts/1L	0.21	0.70	ND	TT	0.00	No	2013	Parasite that enters lakes and rivers through sewage and animal waste.
<b>MICROBIOLOGICAL</b>									
HPC	MPN/mL	31.2	738.0	ND	500.0	0.0	No	2013	High max result is not a violation because the HPC value is calculated into the Not >5% positive Coliform samples per month. Even with this result the 5% was not exceeded.
Total Coliform	% Positive per Month	0.07%	0.78%	0.00%	Not >5%	0.00	No	2013	MCL is for monthly compliance. All repeat samples were negative; no violations were issued. Human and animal fecal waste, naturally occurring in the environment.

mg/L: milligrams per liter  
 ug/L: micrograms per liter  
 pg/L: picograms per liter  
 ng/L: nanograms per liter  
 NTU: Nephelometric Turbidity Unit  
 SOC: Synthetic Organic Chemicals

MCL: Maximum Contaminant Level  
 MCLG: Maximum Contaminant Level Goal  
 TTHM: Total Trihalomethanes  
 HAA5s: Five Haloacetic Acids  
 HPC: Heterotrophic Plate Count  
 SS: Secondary Standard

ND: None Detected  
 NA: Not Applicable  
 NE: Not Established  
 UR: Unregulated  
 TT: Treatment Technique  
 AL: Action Level

1/cm: One / centimeter  
 pCi/L: picocuries per liter  
 MFL: Millions of Fibers per Liter  
 MPN/mL: most probable number per milliliter  
 Oocysts/1L: Oocysts per 1 liter  
 Cysts/1L: Cysts per 1 liter

CU: Color Unit  
 TON: Threshold Odor Unit  
 umhos/cm: micro ohms per centimeter  
 VOCs: Volatile Organic Compounds  
 PCBs: Polychlorinated Biphenyls

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline: 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline: 1-800-426-4791.